


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.

Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen



Rotthauer Str. 21
45879 Gelsenkirchen

Phone (0209) 9242-0
Fax (0209) 9242-222
Internet www.hyg.de

Our reference: W-269068ze-16-Ho
Contact person: Dipl.-Ing. (FH) S. Horn

Test - certificate

hygiene-conformity check to the design requirements
of selected regulations

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauer Straße 21
49879 Gelsenkirchen

Test object: air humidification unit size
"LBE 250" / "LBE 500"

Manufacturer: J.Pichler Lufttechnik Gesellschaft m. b. H.
Karlweg 5
A-9021 Klagenfurt

Basis of the examination: ✓ VDI 6022, Blatt 1 (07/2011)*
✓ SWKI VA104-01 (04/2006)*
✓ VDI 3803, Blatt 1 (02/2010)*
✓ ÖNORM H 6021 (09/2003)

Validity period: 5 years 04/2016 – 04/2021

Test report: W-269068-16-Ho



In conclusion it can be stated that the examined air humidification unit size "LBE 250" / "LBE 500" as specified in the test report W-269068-16-Ho, is in compliance with the design requirements of the above mentioned regulations.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)
Head of the Department of Water
Hygiene and Environmental
Microbiology

(Dipl.-Ing. (FH) S. Horn)
Section head of Air Conditioning technology
Department of Water Hygiene and Environmental
Microbiology

issued 07.04.2016, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Vereinsregister: VR 519 Amtsgericht Gelsenkirchen, USt-ID: DE125018356
Vorstand: Prof. Dr. Werner Schlake (Vors.), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Dr. Dirk Waider, Prof. Dr. Lothar Dunemann (geschäftsführ. Vorstand)