

Specific energy consumption (SEC)	manual control		clock control		central demand control	local demand control
	cold climate	-74,9	-76,2	-78,6	-82,7	[kWh/(m <sup>2</sup> ·a)]
average climate	-35,5	-36,7	-38,8	-42,5	[kWh/(m <sup>2</sup> ·a)]	
warm climate	-10,3	-11,4	-13,5	-16,9	[kWh/(m <sup>2</sup> ·a)]	
<b>Specific energy consumption class</b>	A		A		A	A+ (most efficient)
<b>Type</b> "residential ventilation system", "bidirectional ventilation system"						
<b>Motor and drive</b> variable speed						
					x-value	2 [-]
<b>Type of heat recovery system</b> recuperative						
<b>Thermal efficiency of heat recovery</b>					$\eta_t$	90,9% [-]
<b>Maximum flow rate</b>					$q_{Vd}$	180 [m <sup>3</sup> /h]
<b>Electric power input of the fan drive, including any motor control equipment, at maximum flow rate</b>					$P_E$	98,8 [W]
<b>Sound power level</b>					$L_{WA}$	45 [dB(A)]
<b>Reference flow rate</b>					$q_{Vn}$	126 [m <sup>3</sup> /h]
<b>Reference pressure difference</b>					$p_{tU}$	50 [Pa]
<b>Specific power input</b>					SPI	0,348 [W/(m <sup>3</sup> /h)]
<b>Ventilation control (CTRL)</b>						
local demand control	1	0,95	0,85	0,65	[-]	
<b>Maximum air leakage rate referred to reference flow rate</b>						
internal					$q_{vi} / q_{Vn}$	0,71% [-]
external					$q_{ve} / q_{Vn}$	0,87% [-]

**Filter change**

The filters are to be replaced as soon as:

- the warning light appears on the operator control unit "MINI"
- the command to replace the filters appears on the display of the operator control unit "TOUCH" (marked red in the pictures alongside)



Operator control unit "MINI"



Operator control unit "TOUCH"

**CAUTION:**

If the filters are not changed regularly, the system can not work efficiently and the power consumption increases.

**Waste disposal**

Units that are no longer in working order have to be dismantled and properly disposed of by a specialized company via suitable collection centres and in compliance with the waste electrical and electronic equipment ordinance (WEEE), which provides for ratification of community law, directive 202/95/EC (RoHS) and the directive 2002/96/EC (the WEEE directive).

Annual electricity consumption (AEC)	4Z	4Z	3Z	2Z	QK \ electricity#UQ
<b>Annual heating saved (AHS)</b>					
cold climate	91,6	91,8	92,3	93,1	[kWh primary energy/a]
average climate	46,8	46,9	47,2	47,6	[kWh primary energy/a]
warm climate	21,2	21,2	21,3	21,5	[kWh primary energy/a]

Information based on the current state of knowledge of EU Regulations 1253/2014 and 1254/2014

Download from: [www.pichlerluft.at](http://www.pichlerluft.at)

Responsible for the content: J. Pichler Gesellschaft m.b.H.  
Photos: Archiv J. Pichler Gesellschaft m.b.H. | Text: J. Pichler Gesellschaft m.b.H.  
All rights reserved | All photos are symbolic photos | Subject to change without notice | Version: 05/2017 db