


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Director: Dr. Thomas-Benjamin Seiler

Legal Entity: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



Hygiene-Institut · PO Box 10 12 55 · DE 45812 Gelsenkirchen · Germany

Address:
Rotthäuser Str. 21, DE 45879 Gelsenkirchen

Switchboard +49 (0)209 9242-0
Telefax +49 (0)209 9242-222
Internet www.hyg.de

Our reference: W-340950e-21-Zd
Contact person: Dipl.-Ing. (FH) S. Horn

Gelsenkirchen, 01.04.2021

Test - certificate

hygiene-conformity check to the design requirements of
selected regulations

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthäuser Straße 21
45879 Gelsenkirchen

Test object: Duct silencer SD

Manufacturer: J.Pichler Lufttechnik Gesellschaft m. b. H.
Karlweg 5
A-9021 Klagenfurt

Basis of the examination:

- ✓ VDI 6022, sheet 1 (01/2018)
- ✓ SWKI VA104-01 (01/2019)
- ✓ DIN 1946-4 (09/2018)
- ✓ ÖNORM H 6021 (08/2016)
- ✓ ÖNORM H 6020 (06/2019)
- ✓ ÖNORM H 6038 (02/2020)

Validity period: 5 years 04/2021 – 04/2026

Test report: W-340950-21-Zd

In conclusion it can be stated that the examined Duct silencer SD with silencer splitters SDK, as specified in the test report W-340950-21-Zd, is in compliance with the above mentioned regulations.

(Dipl.-Ing. (FH) S. Horn)
Head of the Department hygienic building technology

(B. Zeidler)
Clerk of the Department hygienic building technology



issued 01.04.2021, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.

Legal Entity: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Register: VR 519 Local Court Gelsenkirchen (Germany); VAT ID: DE125018356
Directorate: Prof. Dr. Jürgen Kretschmann (Head), Dr. Emanuel Grün, Dr. Dirk Waider, Joachim Löchte, Dr. Thomas-Benjamin Seiler (Executive Member).